

Investigation information release

Date: July 2025

Electrician injured from an arcing flash

Incident date: 7 June 2025

Event: Electrician suffers burns from an arcing flash

Location: Appin Mine North (Westcliff colliery), Appin, NSW.

The mine

Appin Mine North – Endeavour Coal Pty Ltd is 6 kilometres form Appin township NSW. This surface infrastructure is part of the greater Appin underground.

The incident

Two electrical tradespersons had completed an internal inspection on a workshop 415V distribution board (DSBW202) at 1.15 pm on 7 June 2025. They were at the isolation point, trying to close the circuit breaker (ACB1) in distribution board (DSBW201).

The circuit breaker would not close, so the workers began fault-finding tasks.

While investigating the function of closing the circuit breaker ACB2, which is adjacent to ACB1, the circuit breaker racking handle was used as a levering tool. During the process, the racking handle inadvertently made contact with a live phase and the enclosure frame (i.e. earthed) causing a phase-to-earth fault and a subsequent arc blast. As a result, one of the workers suffered arc flash burns to his left hand.

The investigation

An investigation is underway into the causes and circumstances of the incident. The investigation will examine the effectiveness of controls to eliminate or minimise the risk to health and safety from this task of electrical fault finding, including but not limited to the:

- adequacy of control plans and procedures
- adequacy of training and supervision
- adequacy of risk management tools and procedures
- duties of persons conducting business undertakings (PCBUs)
- adequacy of plant, equipment and ancillary devices involved in the incident.

Investigation information release IIR25-06

Figure 1: The distribution board involved in the incident



Further information

Please refer to the following guidance materials:

- Position paper Electrical work on, or in, proximity to energised electrical equipment
- Safety Bulletin SB25-04 Electric shocks in the mining industry
- AS/NZS 4836: 2023 Safe working on or near low voltage and extra low voltage electrical installation and equipment.

• AS/NZS 3000: Wiring rules

RDOC24/M 2

Investigation information release IIR25-06

About this information release

The Regulator has issued this information to draw attention to the occurrence of a serious incident in the mining industry. Further information may be published as it becomes available.

Visit our website to:

- learn more about our work on causal investigations and emergency response
- view our publications on other causal investigations

© State of New South Wales through the Department of Primary Industries and Regional Development 2025. You may copy, distribute, display, download and otherwise freely deal with this publication for any purpose, provided that you attribute the Department of Primary Industries and Regional Development as the owner. However, you must obtain permission if you wish to charge others for access to the publication (other than at cost); include the publication in advertising or a product for sale; modify the publication; or republish the publication on a website. You may freely link to the publication on a departmental website.

Disclaimer: The information contained in this publication is based on knowledge and understanding at the time of writing (July 2025) and may not be accurate, current or complete. The State of New South Wales (including Department of Primary Industries and Regional Development), the author and the publisher take no responsibility, and will accept no liability, for the accuracy, currency, reliability or correctness of any information included in the document (including material provided by third parties). Readers should make their own inquiries and rely on their own advice when making decisions related to material contained in this publication.

Document control	
CM10 reference	D25/51942
Mine safety reference	IIR25-06
Date published	9 July 2025
Authorised by	Chief Inspector Office of the Chief Inspector

RDOC24/M 3